



NOTES:

1. PIPE AND FITTINGS ARE TO BE ASTM D3034, GASKETED 4" SDR 26 PVC UNLESS NOTED.
2. THE SERVICE SHALL BE INSTALLED PERPENDICULAR BETWEEN THE SEWER MAIN AND THE BUILDING ENTRY POINT WITH A UNIFORM SLOPE OF NOT LESS THAN 1/4" PER FOOT.
3. REFER TO MANUFACTURER'S SPECIFICATIONS FOR MAXIMUM JOINT DEFLECTION (TYPICALLY ONE DEGREE FOR PVC).

AUTHORITY DOES NOT
PROVIDE BASEMENT SERVICE

**SANITARY LATERAL
SHALLOW SEWER DETAIL**
NOT TO SCALE

REVISED 7/12/22

SANITARY LATERAL-SHALLOW SEWER
PREPARED FOR:
PERKASIE REGIONAL AUTHORITY

**ANDERSEN
ENGINEERING
ASSOCIATES
INCORPORATED**
150 RIDGE ROAD, SUITE 2, SELLERSVILLE, PA 18980
(215) 257-5711

DSN BY: C.J.O.
CHK BY: P.C.A.
DATE: 4/04/96
DWG NO. PRA-S011